

**DEMON MOTOR COMPANY LTD**  
**58, NEW STREET, CHENNAI – 108**

To: The Managing Director

Ref: DMC/155/B9

From: The Safety Engineer

05 May 2009

Sir,

Sub: A report on the fire accident in our Factory – reg.,

With reference to your intimation dated 04 may 2009; a detailed study has been made on the fire accident that took place on the 2<sup>nd</sup> of this month in our factory.

On the above mentioned date, a huge fire had broken out around 11 a.m. in our Welding Department. It spread so quickly that it consumed fairly a large number of tools and spare parts. Above all, Mr.Sai, our chief welder was also badly hurt. Luckily he was the only person working at that time as the other workers had gone for tea break. Immediately, fire men were summoned and they extinguished the fire after battling for about half-an-hour. Mr.Sai was hospitalized and he is now recovering fast.

Under investigation, it is found that the fire broke out because of a short circuit in the main line. As Mr. Sai had been welding at that time, the fire had spread quickly. In addition, the wires had worn out and needed replacement. All these had resulted in the devastating fire. The total loss is estimated to be nearly Rs.1, 50,000.